



A P P R O V A L S ®

Certificate of Suitability

Addendum

Certificate No.: SAA193042

Date of Issue: 6 November 2019

Class Description: Non-Declared

Product Description: Grid-connected PV Inverter

General Modification:

Firmware Version: V1,00

Hardware Version: V1,00

Additional Models	Trade Name	Rating
STS-4.6KTL	sunways	Input: MPP voltage range: 100-550Vdc, Max 600Vdc, Max 2x12.5A, Isc: 2x15A Output: 230V~ 50Hz Max 21A, 4600W, Max 4600VA
STS-4.2KTL	sunways	Input: MPP voltage range: 100-550Vdc, Max 600Vdc, Max 2x12.5A, Isc: 2x15A Output: 230V~ 50Hz Max 21A, 4200W, Max 4600VA
STS-3.6KTL	sunways	Input: MPP voltage range: 100-550Vdc, Max 600Vdc, Max 2x12.5A, Isc: 2x15A Output: 230V~ 50Hz Max 18A, 3600W, Max 3960VA
STS-3KTL	sunways	Input: MPP voltage range: 100-550Vdc, Max 600Vdc, Max 2x12.5A, Isc: 2x15A Output: 230V~ 50Hz Max 15A, 3000W, Max 3300VA


For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 06-11-19 193042/2



A P P R O V A L S ®

Certificate of Suitability

Certificate No.: SAA193042

Certificate Holder: Ningbo Sunways Technologies Co., Ltd.
Green Industrial Zone, Cixi,
No1. Luyuan Road, 315334 Ningbo,
Zhejiang,
P.R. China

Class Description: Non-Declared
Product Description: Grid-connected PV Inverter
Trade Name: sunways
Model No.: STS-5KTL
Markings: Input: MPP voltage range: 100-550Vdc, Max 600Vdc,
Max 2x12.5A, Isc: 2x15A
Output: 230V~ 50Hz Max 25A, 5000W, Max 5500VA
-30°C to +60°C, IP65, Class I

Standard: IEC 62109-1 Ed 1.0
IEC 62109-2 Ed 1.0
AS/NZS 4777.2:2015

Conditions: Nil

Certification Mark: SAA193042 or RCM

Date First Registered: 6 November 2019
Date of Expiry: 6 November 2024


For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 06-11-19 193042/1